

Exhibit B (Page 2 of 2)



Department of Environmental Protection  
Central District

PWS ID #: 3480203

PWS NAME: MAITLAND, CITY OF (3 WPS)

POPULATION: 13,268

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at each POE* every year.
Primary Inorganics	2017-EA. WP	Sample at each POE every 3 years.
Secondaries	2017-EA. WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2020-EA. WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA. WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (Every 90 days)	Continue routine (qtrly) testing at 4 sites for both T/H (dual samples) beginning October 2013. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
* Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- It is important for you to provide this information to your operator and/or sampler.
- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.
- Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.

\* Lead and Copper sampling to be performed with Maitland staff (this requires access and appointments with Maitland’s utility customers).